

WCTMA Water Company Operator's Report

December 2, 2025

- I. Meter Replacement

The operators have been in the process of replacing the meters in the system with Radio Read Meters. (Neptune Meters). The following information is the status of the Meter Replacements.

 1. Number of Meters replaced. (188)
 2. Number of Meters to be replaced. (162)
 3. Number of New Meters for development. (5)
- II. Service Line Inventory Project
 1. Number of responses and entered service Line information. (118)
 2. The total entry of the Initial inventory of 341 entries has been submitted to DEP through the DWELR system. Three Years to complete the final verifications and requirements for the service Lines.
 3. Notice to Customers with Unknown and Galvanized connections sent out November 15th,2025.
 4. Mapping has been entered through Diamond Maps application for the Valves, Curb Stops, and Fire Hydrants. We have attached the pictures with the data in Diamiond Maps.
 5. Five Years to complete the Service Line Inventory.
 6. Updated file has been received from DEP. We wil be adding to the data and updating data to Diamond Maps.
 7. A schedule will be setup for next year to check the Curb stops with the drilling company.
- III. The 30 day Overdue Notices for 3rd Quarter Billing went out October 15th.
- IV. Well Depth device for water company

Issue with 123SCADA system was not transferred to WCTMA for billing. Waiting until the issue is resolved before getting estimates for in well depth analyzers.
- V. Emergency Generator for Water Company
 1. Lost Power on November 5th.
 2. Lost Power on November 6 Temporarily. Back on around noon.
 3. Lost Power on November 15th due to a squirrel shorting out a transformer.
 4. Lost Power on December 2nd Temporarily for about 40 minutes.
 5. Reviewing power generators and options for the Water Company.
- VI. Software for the water company and tracking for Service Locations and Work Orders.
 1. Current Software from gWorks was more than what we need for the indicated tasks. Signed up for another year to continue to use UBmax Software.
 2. We can use UBMAX until we find another Software Package.
 3. Review Notification Software for the water company.
- VII. SCADA System software to be transferred to the WCTMA for Billing.
- VIII. Updated Well Production Information Report for 2025 attached to this report.

Well Production Information 2025

Well Number	January	February	March	1st QTR Total	April	May	June	2nd QTR Total
101	391288	113595	169093	673976	107672	130032	114295	351999
103	1006791	809817	609178	2425786	428431	463197	338710	1230338
104	855945	851986	983041	2690972	1048549	824609	1105509	2978667
Total Production:				5790734				4561004
Distribution Information								
Entry Point	2198861	1848379	1816138	5863378	1564386	1389483	1549306	4503175
Chlorine Gallons Used	25	26	27	78	24	23	16	63
Phosphorus Galloms Used	5	4	4	13	5	4	5	14

July	August	September	3rd Qtr Total	October	November	December	4th Qtr Total
118641	119656	127544	365841	132060	404611		536671
364288	379583	333277	1077148	353382	978171		1331553
1074559	1084712	1075510	3234781	1032325	172304		1204629
			4677770				3072853
1521506	1520560	1552761	4594827	1490392	1486706		2977098
22	21	22	65	26	6		32
4	5	5	14	4	1		5